

From: Jerry Cuttler [<mailto:jerrycuttler@rogers.com>]
Sent: Friday, October 12, 2012 5:15 PM
To: Consultation
Subject: Comments from Dr. Cuttler FW: Invitation to comment on draft guidance GD-337, Guidance for the Design of New Nuclear Power Plants

Hi Folks

I read through DRAFT GD-337 hoping to find clarification on the requirements that appear in RD-337 version 2, Section 8.4 on Means of Shutdown.

1. I understand the following requirements:

"The design shall provide means of reactor shutdown capable of reducing reactor power to a low value, and maintaining that power for the required duration, when the reactor power control system and the inherent characteristics are insufficient or incapable of maintaining reactor power within the requirements of the OLCs.

The design shall include two separate, independent, and diverse means of shutting down the reactor.

At least one means of shutdown shall be independently capable of rendering the reactor subcritical from normal operation, in AOOs and in DBAs, and maintaining the reactor subcritical by an adequate margin and with high reliability, for even the most reactive conditions of the core."

However, I do not understand the requirement below very well. I was expecting the DRAFT GD-337 to explain this.

"At least one means of shutdown shall be independently capable of quickly rendering the nuclear reactor subcritical from normal operation, in AOOs and DBAs, by an adequate margin, on the assumption of a single failure. For this means of shutdown, a transient recriticality may be permitted in exceptional circumstances if the specified fuel and component limits are not exceeded."

Since it is assumed that one means of shutdown could fail unsafely, why is the other means of shutdown not required to have the same performance capabilities as required for means of shutdown that failed?

2. I understood from the meaning of AOOs, that they are to be managed by the reactor control system, not by the safety systems (the means of shutdown). And I understood that if the reactor control system is incapable of controlling an AOO then the event is not an AOO but really a design basis accident (DBA). So, the reactor trips should be for DBAs (and DECAs), not for AOOs and DBAs. However, RD-337 states in Section 8.4.1 that reactor trips are to be initiated for AOOs and DBAs. GD-337 does not clarify the confusion created by requiring the safety system to trip for AOOs (in addition to DBAs).

Please clarify in GD-337 or revise RD-337 to remove AOOs from the role of safety systems.

Jerry Cuttler
jerrycuttler@rogers.com